

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-14-12-15-01

Product: Krono Xonic, different decors
Thicknesses: 4 mm - 5 mm

Producer: Kronoflooring GmbH Lampertswalde/Dresden
Mühlbacher Straße 1
01561 Lampertswalde

Order: Testing and classification of selected properties according to EN 14041:2008 (CE-labelling)

Test report: 2714296 / 271109 / 2614211

Test results:


Property	Declaration according to EN 14041:2008
Reaction to fire performance according to EN ISO 9239-1 and EN ISO 11925-2, classification according to EN 13501-1	B _{fl} -s1
Anti-sliding properties according to EN 13893	class DS
Thermal resistance according to EN 12667	0.06 (m ² K)/W

Dresden, 15 December 2014



Head of laboratory




Engineer in charge